

# CONCRETE SUBSTRATE READINESS CHECKSHEET

## for Tanking Membrane Installation

### bituBOND



<b>Project/Site Name</b>	
<b>Site Address</b>	
<b>Applicator</b>	
<b>Main Contractor</b>	

QC process	✓	Tick when completed
Surface smooth and clean.	<input type="checkbox"/>	
Cavities and cracks filled with repair mortar and flushed off.	<input type="checkbox"/>	
Concrete surface firm with any soft concrete or latescence removed.	<input type="checkbox"/>	
Roof drains and overflow recesses formed to fit.	<input type="checkbox"/>	
Mortar fillets to all upstands and smooth – 5mm radius to all external edges.	<input type="checkbox"/>	
If terminating into a chase, pre-form the chase and ensure that it is straight and 20mm deep.	<input type="checkbox"/>	
Concrete cured and thoroughly dry.	<input type="checkbox"/>	
Substrate clean, firm and in suitable condition for laying.	<input type="checkbox"/>	
Flush point the surface of Polystyrene blocks.	<input type="checkbox"/>	

**WHEN THE SUBSTRATE IS READY, COMPLETE THIS FORM AND EMAIL TO THE WATERPROOFING SUBCONTRACTOR.**

<b>Notes</b>			
<b>Name</b>			
<b>Signature</b>		<b>Date</b>	